

MATERIAL

EPOXY COATED

CAST IRON

STAINLESS STEEL


STAINLESS STEEL


STAINLESS STEEL


EPDM

PTFE

NBR







PART NAME

BODY

DISC

SPRING

SHAFT

SEAT

WASHER

SEAL

MAX NON-SHOCK WORKING PSI

SIZE	150°F	200°F
2" TO 12"	200 PSI	190 PSI
14" AND UP	150 PSI	135 PSI

LEAD FREE

The wetted surface of this product contacted by consumable water contains less than one quarter of one percent (0.25%) of lead by weight. Material complies with state codes and standards, where applicable, requiring reduced lead content.

Notes:

Valve is designed for liquid service only. Install 5 to 10 pipe diameters downstream from pump discharge or elbows. To avoid turbulence, use with a VANEFLEX connector.

Valve is designed to be mated to ANSI B16.5 steel flanges.

For vertical pipe, install with flow up. For horizontal pipe,

8		SET S	SET SCREW		STAINLESS STEEL		install with hinge pin in vertical position.			
Qty.	Part	Number	Size I.D. (in)	A (in)	B (in)	C (in)	Cv*	Weight (Lbs)	Bolt Size (in)	Project Info
	CV	XXK0200	2	4	1-3/4	1/4	48	3	5/8	
	CV	XXK0250	2-1/2	4-3/4	1-7/8	5/8	99	5	5/8	
	CV	XXK0300	3	5-1/4	2-1/2	1/2	171	8	5/8	
	CV	XXK0400	4	6-3/4	2-1/2	1-1/8	290	13	5/8	
	CV	XXK0500	5	7-5/8	2-3/4	1-3/8	489	16	3/4	
	CV	XXK0600	6	8-5/8	3	1-5/8	695	20	3/4	
	CV	XXK0800	8	10-7/8	3-1/2	2-7/8	1789	38	3/4	
	CV	XXK1000	10	13-1/4	4-1/2	3	2557	57	7/8	
	CV	XXK1200	12	16	4-1/2	4-5/8	4287	93	7/8	
	CV	XXK1400	14	17-5/8	5	5	5456	121	1	
	CV	XXK1600	16	20	5-1/2	5-3/4	7342	165	1	
	CV	XXK1800	18	21-1/2	6	6-3/8	9532	223	1-1/8	
	CV	XXK2000	20	23-3/4	6	7-1/8	12000	245	1-1/8	

*Cv is the number of U.S. gallons/minute of 60°F water that will flow through a valve with 1 PSI of pressure drop across the valve.



ENGINEER:

ITEM

1

2

3

4

5

6

FOR ADDITIONAL FLOW STRAIGHTENING SEE THE VANEFLEX AT www.metraflex.com/vaneflex

CUSTOMER:_	 	
PROJECT:		

REV.		DATE
Met for pipes in	rafic	2323 W. HUBBARD ST. CHICAGO, IL 60612 TEL: 312-738-3800 FAX: 312-738-0415 WWW.METRAFLEX.COM

MODEL CVXXK

125# SPLIT DISC WAFER STYLE CHECK VALVE

DRAWN BY: **DKISH** DATE: **8/27/2013** APPROVED: JC DATE: 8/27/2013

SCALE: DRAWING NUMBER: CVXXK-EP